



FOR REFERENCE ONLY; NOT FOR CONSTRUCTION.  
Installer responsible for code compliance.

Published: 01/29/19

This design shows a Pika Energy Island ready for net-metering sourced by PV power. There are un-utilized DC inputs that may be utilized for additional PV or to add battery storage in the future.

**Line-Side Tap / Storage Ready [1113-01]**

- 3 PV Links
- 1 REbus Beacon
- 1 Islanding Inverter

This configuration is acceptable with most 200A residential services.

